



# *Aberdeen High School*

251 Paradise Road, Aberdeen, Maryland 21001  
410-273-5500

Michael J. Quigg, Principal

Sarah K. Doyle, Assistant Principal  
Lamark A. Holley, Assistant Principal  
Monisha J. Thomas, Assistant Principal  
Mark C. Truszkowski, Assistant Principal

## Lead in Drinking Water – Public and Nonpublic Schools

### **IMPORTANT NOTICE: ELEVATED WATER SAMPLE RESULT** **Aberdeen High School**

#### **ELEVATED LEAD WATER SAMPLE RESULT**

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On January 12 and February 28, 2019, two hundred ninety-one (291) lead water samples were collected from Aberdeen High School. Of these lead water samples, **six** had levels of lead exceeding the action level of 20 parts per billion (ppb) for lead in drinking water in school buildings. The elevated lead results from the samples collected at Aberdeen High School were as follows:

**61.8 parts per billion (ppb) C122 Project storage room sink off of C124**

**24.3 parts per billion (ppb) H103 sink, left, third left**

**34.4 parts per billion (ppb) H103, teacher's sink**

**75.9 parts per billion (ppb) C102 sink, right, middle**

**38.9 parts per billion (ppb) A223 sink**

**36.7 parts per billion (ppb) B206 sink, left**

#### **ACTION LEVEL (AL)**

The AL is 20 ppb for lead in drinking water in school buildings. The AL is the concentration of lead which, if exceeded, triggers required remediation.

#### **HEALTH EFFECTS OF LEAD**

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

#### **SOURCES OF HUMAN EXPOSURE TO LEAD**

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the work place and exposure from certain hobbies, brass

---

*The mission of Aberdeen High School is to inspire students to contribute wisdom, integrity, patriotism, compassion, and leadership to a global society. We provide a rigorous, academic program where accountable educators lead students to take responsibility for learning and achievement.*



# *Aberdeen High School*

251 Paradise Road, Aberdeen, Maryland 21001  
410-273-5500

Michael J. Quigg, Principal

Sarah K. Doyle, Assistant Principal  
Lamark A. Holley, Assistant Principal  
Monisha J. Thomas, Assistant Principal  
Mark C. Truszkowski, Assistant Principal

---

faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

## **IMMEDIATE ACTIONS TAKEN**

Results were received on August 13, 2019. Handwash only signs were placed at the sinks.

## **NEXT STEPS**

At this time our remedial action is to use these sinks for hand washing only.

## **TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:**

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

*Please note that boiling the water will not reduce lead levels.*

## **ADDITIONAL INFORMATION**

1. For additional information, please contact **Patti Jo Beard, Harford County Public Schools**, at **410-638-4088**. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at [www.epa.gov/lead](http://www.epa.gov/lead). If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.